

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY  
CONDITION CERTIFICATE**

No. ....617.....

Date : ....28/10/2025.....

It is certified that an inspection team headed by .....

AEN, PHED, Pilani.

Inspected the **VIDYA NIKETAN, BIRLA PUBIC SCHOOL, PILANI** on .....

As per the water samples collected from the school are potable and safe for drinking. The found water is safe for drinking and good for health condition for the students and staff of the institution. The hygiene sanitation condition in the school building & campus as per the norms prescribed by the Central/State/UT Govt.

The above certificate is valid for a period of.....6 Months.....

Signature with seal.....

सहायक अभियन्ता  
जन स्वास्थ्य अभि. विभाग

Name.....

उपखण्ड पिलानी (सुन्डुनी)  
कोड नं CRW149

Designation.....

**PUBLIC HEALTH ENGINEERING DEPARTMENT  
LABORATORY JHUNJHUNU**

**CHEMICAL EXAMINATION REPORT OF WATER**

No. Lab. / Chem. /2025-26/ 585

Date - 8-10-2025

To,

Vidya Niketan  
(Birla Public School)  
Pilani

District - Jhunjhunu

Tehsil:- Pilani

Ref- Your letter no.BPS/2025-26/Pub.Health Deptt dated 4-10-2025

Date of Exam -8-10-2025

A	Name & Location of Source	IS-10500:2012		Water Sample Birla Public School
B	Village/ Town			Pilani
C	Date Of Collection			4-10-25
D	Lab. Sample No.			C-103
Sr. No	Parameters			Value
1	pH			6.57
2	Turbidity[NTU]			Nil
3	Temperature[C]			25
4	Colour[Units]			None
5	Odour			Unobj.
6	Residual Chlorine			Nil
7	Total Alkalinity[asCaCO <sub>3</sub> ]			30
8	Total Hardness[asCaCO <sub>3</sub> ]			20
9	Chloride[asCl <sup>-1</sup> ]			28
10	Nitrate[as NO <sub>3</sub> <sup>-1</sup> ]			03
11	Fluoride [as F <sup>-1</sup> ]			0.11
12	Sulphate [as SO <sub>4</sub> <sup>-2</sup> ]			04
13	TDS			94

Note:1- All Results Except pH in mg/L.

2- This report is not valid for legal cases/legal purposes.

(S K Sharma)

Junior Chemist .

PHED Laboratory Jhunjhunu